



◆ **TILE INSTITUTE of AMERICA** ◆

1262 Bouquet Circle, Thousand Oaks, California 91362 Telephone: (805) 371-TILE (8453) Facsimile: (805) 371-8453
 23825 15th Avenue SE #110, Bothell, Washington 98021 240 Makee Road, Suite PH-A, Honolulu, Hawaii 96815
DoctorTile@aol.com DoctorTile1@gmail.com [\(805\) 444-8453](tel:(805)444-8453)

TIA's Client: 20201228 BS

Aquabella USA, LLC
Mr. Brian L. Streadbeck
450 South Alpine Highway
Alpine, Utah 84004

Telephone: (833) 985-2955
info@aquabellatile.com

Tile: Monet Series

MS-1180 - IMPRESSION S.R. 1X1	MS-1185 - STORMY 1X1	MS-1284 - PARADISE 1X2	MS-883 - HAYSTACK BLOCK RANDOM
MS-1181 - WATER LILIES 1X1	MS-1186 - SAILBOAT 1X1	MS-1285 - STORMY 1X2	MS-884 - PARADISE BLOCK RANDOM
MS-1181L - WATER LILIES L 1X1	MS-1280 - IMPRESSION S.R. 1X2	MS-1286 - SAILBOAT 1X2	MS-885 - STORMY BLOCK RANDOM
MS-1182 - VENICE 1X1	MS-1281 - WATER LILIES 1X2	MS-880 - IMPRESSION S.R. BLOCK	MS-886 - SAILBOAT BLOCK RANDOM
MS-1183 - HAYSTACK 1X1	MS-1282 - VENICE 1X2	MS-881 - WATER LILIES BLOCK	
MS-1184 - PARADISE 1X1	MS-1283 - HAYSTACK 1X2	MS-882 - VENICE BLOCK RANDOM	

Conditions: New tiles sent to TILE INSTITUTE of AMERICA in sealed manufacturer's boxes from client above and selected at random.

Report of Test

STAIN RESISTANCE (T-72)

Standard Test Method for Stain Resistance of Ceramic Tile. This method provides the means for establishing whether this tile can resist staining from six commonly used materials, which may appear in tile specifications. The tile samples were prepared as

per specifications with the common household materials (each material having one sample covered with a Petri dish and the other uncovered) and left for 24 hours, and then cleaned with Ajax Industrial Cleaner and water

Observation of Surface Stain

Sample Tiles	Staining Materials	Uncovered	Covered
1.	Coca Cola	No Stain	No Stain
2.	Lemon Juice	No Stain	No Stain
3.	Mustard	No Stain	No Stain
4.	Bacon Grease	No Stain	No Stain
5.	Catsup	No Stain	No Stain
6.	Wesson Oil	No Stain	No Stain

Requirements: When tested as described. No evidence of any surface stain remaining, and all traces of the staining materials can be washed from the tile's surface.

Test Results: **Pass**

Sincerely,

A handwritten signature in cursive script that reads "Gerald M. Halweg". The signature is written in black ink and is positioned above the typed name and title.

Gerald M. Halweg, CTC, CSI, TTA. Date: July 1, 2021
President/CEO of TILE INSTITUTE of AMERICA