



TILE INSTITUTE of AMERICA

1262 Bouquet Circle, Thousand Oaks, California 91362 Telephone: (805) 371-TILE (8453) Facsimile: (805) 371-8453
23825 15th Avenue SE #110, Bothell, Washington 98021 240 Makee Road, Suite PH-A, Honolulu, Hawaii 96815
DoctorTile@aol.com DoctorTile1@gmail.com (805) 444-8453

TIA's Client: 20201228 BS

Aquabella USA, LLC
Mr. Brian L. Streadbeck
450 South Alpine Highway
Alpine, Utah 84004

Telephone: (833) 985-2955
info@aquabellatile.com

Tile: **Abyss Series**

AY-620 - PORT ROYAL 6X6	AY-220 - PORT ROYAL 2X2	AY-620 SBN - PORT ROYAL 6X6 S	AY-620 DECO - PORT ROYAL 6X6
AY-621 - ATLANTIS 6X6	AY-221 - ATLANTIS 2X2	AY-621 SBN - ATLANTIS 6X6 S	AY-621 DECO - ATLANTIS 6X6
AY-622 - THONIS 6X6	AY-222 - THONIS 2X2	AY-622 SBN - THONIS 6X6 S	AY-622 DECO - THONIS 6X6
AY-623 - ALEXANDRIA 6X6	AY-223 - ALEXANDRIA 2X2	AY-623 SBN - ALEXANDRIA 6X6 S	AY-623 DECO - ALEXANDRIA 6X6
AY-624 - TIKAL 6X6	AY-224 - TIKAL 2X2	AY-624 SBN - TIKAL 6X6 S	AY-624 DECO - TIKAL 6X6

Conditions: New tiles sent to TILE INSTITUTE of AMERICA in sealed manufacturer's boxes from client above and selected at random.

Report of Test

STAIN RESISTANCE (T-72)

Standard Test Method for Stain Resistance of Ceramic Tile. This method provides the means for establishing whether this tile can resist staining from six commonly used materials, which may appear in tile specifications. The tile samples were prepared as per specifications with the common household materials (each material having one sample covered with a Petri dish and the other uncovered) and left for 24 hours, and then cleaned with Ajax Industrial Cleaner and water.


Observation of Surface Stain

Sample Tiles	Staining Materials	Uncovered	Covered
1.	Coca Cola	No Stain	No Stain
2.	Lemon Juice	No Stain	No Stain
3.	Mustard	No Stain	No Stain
4.	Bacon Grease	No Stain	No Stain
5.	Catsup	No Stain	No Stain
6.	Wesson Oil	No Stain	No Stain

Requirements: When tested as described. No evidence of any surface stain remaining, and all traces of the staining materials can be washed from the tile's surface.

Test Results: **Pass**

Sincerely,


Gerald M. Halweg, CTC, CSI, TTA. Date: July 1, 2021
President/CEO of TILE INSTITUTE of AMERICA