



**TILE**

TILE INSTITUTE of AMERICA

**MERICA**

1262 Bouquet Circle, Thousand Oaks, California 91362 Telephone: (805) 371-TILE (8453) Facsimile: (805) 371-8453  
23825 15<sup>th</sup> Avenue SE #110, Bothell, Washington 98021 240 Makee Road, Suite PH-A, Honolulu, Hawaii 96815  
[DoctorTile@aol.com](mailto:DoctorTile@aol.com) [DoctorTile1@gmail.com](mailto:DoctorTile1@gmail.com) (805) 444-8453

TIA's Client: 20201228 SR

**Aquabella USA, LLC Mr.  
Brian L. Streadbeck 450 South  
Alpine Highway Alpine, Utah  
84004**

**Tile: North Seas Series**

Telephone: (714) 264-8269 Facsimile: (714) 685-0465  
[brett@aquabellatile.com](mailto:brett@aquabellatile.com), [brian@msagallery.com](mailto:brian@msagallery.com)

**NS-113 Caspian, NS-114 Norwegian, NS-115 Irish, NS-119 Adriatic, NS-120 Denmark, NS-1225 Arctic, NS-1219 Adriatic, NS-1220 Denmark, NS-1215 Irish, NS-1217 Baltic, NS-1216 Celtic, NS-1214 Norwegian, NS-1213 Caspian, NS-1212 Iceland, NS-1211 Greenland, NS-1210 Polar, NS-110 Polar, NS-111 Greenland, NS-112 Iceland.**

Conditions: New tiles sent to TILE INSTITUTE of AMERICA in sealed manufacturer's boxes from client above and selected at random.

**Report of Test**  
**STAIN RESISTANCE (T-72)**

Standard Test Method for Stain Resistance of Ceramic Tile. This method provides the means for establishing whether this tile can resist staining from six commonly used materials, which may appear in tile specifications. The tile samples were prepared as per specifications with the common household materials (each material having one sample covered with a Petri dish and the other uncovered) and left for 24 hours, and then cleaned with Ajax Industrial Cleaner and water.

**Observation of Surface Stain**

<u>Sample Tiles</u>	<u>Staining Materials</u>	<u>Uncovered</u>	<u>Covered</u>
1.	Coca Cola	No Stain	No Stain
2.	Lemon Juice	No Stain	No Stain
3.	Mustard	No Stain	No Stain
4.	Bacon Grease	No Stain	No Stain
5.	Catsup	No Stain	No Stain
6.	Wesson Oil	No Stain	No Stain

**Requirements:** When tested as described. No evidence of any surface stain remaining, and all traces of the staining materials can be washed from the tile's surface.

Test Results: **Pass**

Sincerely,

Gerald M. Halweg, CTC, CSI, TFA. Date: July 1, 2021

President/CEO of TILE INSTITUTE of AMERICA